

Myra Mason

From: Mark Edsall [mje@mhepc.com]
Sent: Friday, August 29, 2008 11:58 AM
To: Myra Mason; jerry@argeniobros.com
Subject: FW: Nowicki 07-14 (Area of Disturbance)

FYI

From: Mark Edsall
Sent: Friday, August 29, 2008 11:57 AM
To: John Tarolli
Subject: Nowicki 07-14 (Area of Disturbance)

John

After we spoke I had our Stormwater Specialist (PE/CPESC) review the plan.

He tells me there is clearly at least 7+ acres in permanent and temporary disturbance which would therefore require a SWPPP.

Please proceed as previously requested.

If you still disagree, please submit a worksheet showing specific limits of disturbance and areas for each sub area and the total disturbance.

Mark

Mark J. Edsall, P.E.

Principal

McGoey Hauser & Edsall
Consulting Engineers, P.C.
33 Airport Center Drive - Suite #202
New Windsor, New York 12553
(845) 567-3100